

THE PW-200 IS ESPECIALLY DESIGNED TO EXHAUST A COMBINATION OF WASH-ROOMS AND DRYER ROOM. IT HAS BEEN MANUFACTURED WITH ASPECIAL LINT-FREE IMPELLER*

*MINIMUM CFM FOR VENTILATION AND/OR INTERCON-NECTIONS OF DUCTS AND FANS COULD BE REGULATED BY YOUR LOCAL BY-LAWS. VERIFY ACCEPTANCE OF INSTALLATION WHEN NECESSARY

XL SERIES


PW-200 DRYER AND BATHROOM EXHAUST FAN



June, 2006

Reversomatic Manufacturing Ltd.

790 ROWNTREE DAIRY ROAD = WOODBRIDGE, ONTARIO, CANADA L4L 5V3 = PHONE (905) 851-6701 = FAX (905) 851-8376 www.reversomatic.com ï EMAIL info@reversomatic.com



		RPM	AMPS	HP	S.P.	.0	.05	.10	.20	.30	.40	.50	.55
	PW-200	1670	1.15 to 1.33	1/35	CFM	170	162	154	136	118	98	68	52
DDM (Develutions now minute) shown is nominal and notiferrooms is based on estual													

RPM (Revolutions per minute) shown is nominal and performance is based on actual speed